

A panorama of solar PV systems on the roof of Infosys EC-53 building



# An Efficiency Benchmark for the Building Industry

By Guruprakash Sastry Regional Head - Infrastructure, Infosys Limited, Bengaluru

## Introduction

Buildings account for over one third of global energy consumption and are responsible for an equally significant amount of carbon dioxide (CO<sub>2</sub>) emissions. In the Indian context, with rapid urbanization and growing energy demand, it is essential to make sure that the upcoming building stock is built in the most efficient way. The fact that 70% of the India of 2030 is yet to be built provides a great opportunity for the building industry fraternity to transform the way buildings are designed and to adopt a sustainable approach. Though renewable energy sources like solar photovoltaic (PV) are getting cheaper by the day and are witnessing tremendous growth, it is important to understand that the first step to being sustainable is to bring down the demand (energy, water, materials, etc.) through resource efficiency measures, and the second step is to meet the demand through renewables, recycling, etc.

While the building industry embarks on the path of efficiency, it helps to have a building efficiency benchmark to guide design and operations. The benchmark should be unreasonable and challenging, but at the same time practically achievable. One such benchmark is the Infosys EC-53 building, which was inducted into the *ACREX Hall of Fame* in 2017.

## About the Author

**Guruprakash Sastry** is a building industry professional with over 12 years of experience. Currently, as Regional Head – Infrastructure at Infosys, he is responsible for driving sustainability initiatives across Infosys campuses. These include energy efficient façades, efficient HVAC systems and efficient water and waste water treatment systems. He has been instrumental in implementing several innovative HVAC technologies in buildings including the first radiant cooled building in India.

## Building Features

The Infosys EC-53 building, located in Electronics City, Bengaluru is a combination of innovation and excellence in building design and operation. Sustainability measures were an integral part of the design right from the concept stage, and included the building envelope, innovative cooling system, energy metering, automation and continuous performance monitoring. The salient features of the building are described below.

### Pushing the Envelope

Building envelope is the most important aspect of an efficient building design and can impact up to 50% of cooling demand. While most critics would vote against insulation in a moderate climate like Bengaluru, the EC-53 building has a fully insulated high performance envelope. This includes insulated walls (U value: 0.4 W/m<sup>2</sup>K), insulated roof (U value: 0.3 W/m<sup>2</sup> K) and high performance glass and shading for windows. What this has resulted in is

*This article is being published simultaneously in the June 2017 issue of REHVA Journal.*

*continued on page 56*

continued from page 54

an exceptionally low cooling requirement of about 160 TR<sup>1</sup> at peak for a building area of about 15000 m<sup>2</sup> (160,000 ft<sup>2</sup>). High performance spectrally selective glass (light transmission of 42%, solar factor of 0.22 and U value of 1.05 W/m<sup>2</sup> K) and shading on windows has ensured that there is ample natural light inside the building and at the same time occupants feel comfortable without glare or heat radiation from the windows.



Figure 1: Natural day-lighting

### Selecting the Right Systems and Efficient Equipment

The second most important step for achieving a high performance building is to select the most efficient system for the building. LED lighting is used throughout the building to ensure low energy consumption and low maintenance due to the long life of LED lamps. All rest rooms are equipped with motion sensors that ensure lights are kept off when there is no occupancy.



Figure 2: Efficient LED lighting in the building

The EC-53 building was the first in India to implement a radiant panel based cooling system. The radiant panels (supplied by Uponor) are in the form of ceiling tiles and have small pipes within them through which cold water at 16°C is circulated to take care of the sensible load in the building. One floor of the building uses radiant panels developed by the Infosys team to achieve cost effectiveness and higher cooling efficiency. Air handling units take care of the latent load in the building and are equipped with two cooling coils – one with 16°C chilled water and the other with 7°C chilled water.

$${}^1\text{TR} = 3.517 \text{ kW}$$



Figure 3: Uponor radiant panel system



Figure 4: Radiflux radiant panels developed by Infosys team

Other important features of the HVAC system include:

- All equipment with variable speed drives (chillers, pumps, cooling towers, AHUs).
- Magnetic bearing chillers for high efficiency and low maintenance.
- Automatic tube cleaning system to ensure chiller efficiency.
- Dual source units (DX + chilled water) for critical areas like server rooms.

With all these interventions in HVAC, the annual average efficiency of the chiller plant (chiller, pumps and cooling tower) was measured to be 0.42 kW/TR.

### Performance Monitoring

An efficient design does not always translate into efficient operation if the right metering and performance measurement is not carried out. The EC-53 building is equipped with a Building Management System (BMS) with accurate sensors that enable efficient operation of building systems including proper scheduling and control of different equipment remotely. The role of the BMS does not end here. Smart algorithms defined in the BMS make sure the systems ramp up or down based on the building requirement. The efficiency of various equipment like chillers and pumps is continuously tracked with respect to their design curves, and any deviation is highlighted to enable the operations personnel take appropriate action. Any critical parameter going out of range triggers an alarm and notification to the operations personnel so that any equipment failure can be foreseen and preventive action taken. Effective use of BMS for control as well as continuous performance monitoring of the building is a distinguishing feature of the EC-53 building and several other buildings of Infosys.

continued on page 58

continued from page 56

Granular metering in the building enables study of energy patterns among different systems in the building, and helps in focusing action on the right system to minimize energy consumption. Separate energy meters for lighting, computers, ceiling fans and other plug loads at the floor level give an accurate account of energy consumption and identify opportunities for savings.

Table 1: Floor wise energy consumption

Floor Energy Summary Lighting, Fans, UPS & Raw Power											
Floor	Lighting			Raw Power		Fans			UPS Work-station		
	Inst. kW	Target kW Unocc Mode	No. of Lights ON	Inst. kW	Target kW Unocc Mode	Inst. kW	Target kW Unocc Mode	No. of Fans ON	Inst. kW	Target kW Unocc Mode	No. of PCs ON
Gr. Floor	0.0	0.2	0	1.9	0.1	0.0	0.0	0	11.3	5.2	141
1 <sup>st</sup> Floor	1.6	0.0	41	0.1	0.0	0.0	0.0	0	9.6	3.3	120
2 <sup>nd</sup> Floor	3.6	0.1	89	0.6	0.1	0.0	0.0	0	12.3	0.9	154
3 <sup>rd</sup> Floor	3.5	0.2	87	1.8	0.1	0.0	0.0	0	15.0	3.1	187
4 <sup>th</sup> Floor	0.6	0.1	14	1.1	0.1	0.0	0.0	0	11.3	0.1	141
5 <sup>th</sup> Floor	2.1	0.1	52	0.7	0.1	0.0	0.0	0	7.7	2.4	96
6 <sup>th</sup> Floor	1.6	0.1	41	..	0.1						
<b>Total</b>	<b>13.0</b>	<b>0.1</b>	<b>324</b>	<b>6.1</b>	<b>0.2</b>	<b>00</b>		<b>0</b>	<b>67.2</b>	<b>16.0</b>	<b>839</b>



Figure 5: Central Command Center for monitoring performance

## Solar Energy

The EC-53 building has an installed capacity of 90 kWp solar PV plant on the rooftop. A unique feature of the plant is that it consists of 5 different solar technologies of equal capacity on the same roof. This makes for a very accurate comparison between



Figure 6: Different solar PV technologies on the roof of EC-53 building

different technologies for the same weather parameters including temperature, humidity, dust, etc. The technologies installed are monocrystalline, polycrystalline, HIT, CIS thin film and Cd-Te thin film. The plant is able to meet about 10% of the energy requirement of the building on an annual basis.

## Water Wise

Water is a precious resource, the value of which is inadequately understood by the society today. Water scarcity is a serious problem that is increasing every day. When a significant population of the country does not have access to clean water, it is all the more imperative to use the available water most judiciously and harvest every drop of rainwater.

The Infosys EC-53 building has a very low water demand of 25 litre per person per day in all (15 litre fresh water and 10 litre recycled water), owing to low flow fixtures, dual flush toilets, waterless urinals, etc. Hundred percent of the wastewater is recycled in the Sewage Treatment Plant (STP), and the recycled water is used for flushing, irrigation and cooling tower makeup requirements. Rooftop rainwater is harvested in a dedicated tank and used for potable purposes. Last year, about 42% of the fresh water requirement in monsoon months was met through rainwater.

## Benchmarking Parameters

- Energy Performance index (EPI): 84 kWh/m<sup>2</sup> per annum (includes all the energy consumed in the building) for 100% daytime occupancy and 50% night time occupancy.
- Building peak electrical load: 2.85 W/ft<sup>2</sup> (peak observed at building in-comer in a year).
- Light Power Density (LPD): 0.5W/ft<sup>2</sup>.
- Peak cooling capacity: 1000 ft<sup>2</sup> per TR.
- Chiller plant efficiency: 0.42 kW/TR (annual average).
- Solar PV plant capacity: 90 kWp (meets about 10% of annual energy requirement).
- Water requirement: 25 litre per person per day.

## Conclusion

All the above strategies are replicable for other buildings as well. The cost of the building is not higher than a regular building. At Infosys, we have consistently observed that efficient buildings are less expensive than regular buildings when there is a focus right from the initial design stage. It only requires a small additional effort at the design stages and setting the expectations right for the entire design team. It requires questioning every assumption and frugal engineering. It requires rejecting thumb rules and adopting a data driven approach. Most importantly, it requires will from the entire design team including the owner to achieve a sustainable high performance building. ❄