


REBATE- ENERGY
MANAGEMENT



What is Hussmann's Rebate Management Program?

Utility Rebate Programs are a great way to get money back on your energy investments, however, their programs can be tricky and time consuming!

Let Hussmann make the process EASY!

- **Hussmann** manages and coordinates EVERY step in the rebate process on your customer's behalf
- Hassle free process for you! Little to no time or effort required!
- Captures rebates for your project, putting **money** back in your pocket
- We have experience managing full store upgrades, small retrofits, and multisite (300+ store) rollouts
- Leverage relationships with utilities across the country to find solutions for your projects





What is a rebate inquiry?

- Request for information about available rebates in an area, or multiple areas
- May be specific to a project scope, or, more general as a sales tool

When are these requested?

- Generally, requests are received when it's believed the rebate would help close the deal on a project
- Often requested for retrofit and remodel projects, and sometimes new construction
- Rebates can also help fill the gap when project paybacks are slightly higher than the customer would like to see
- Usually considered on multisite rollouts
- When the Requestor just wants to be informed about rebates in their area



UPDATE CRM

All new requests should come through CRM to the "department requests" tab on the left hand side of CRM

filter to the "All Energy Rebate Opportunity" view

Filter rebate opportunity status to pending.

Once determined that a rebate is available and a RM agreement has been signed change the status to "converted"

This will then automatically move this line item to the "Energy Rebates" tab on the left hand side of CRM.

"Energy Rebates" is where our "Master Tracker" is housed.

NOTE: If for some reason there is not an opportunity to tie the rebate to in CRM you will need to create a department request for this rebate request under the opportunity # 147705. This is the Rebate opportunity we created for this scenario.




General Systems Rebate Opportunity Sub Tasks Dates Related ▾

DEPARTMENTS

| | | |
|----------------------------------|-------------------------------------|-----|
| Include Equipment | <input type="checkbox"/> | No |
| Include Systems (AE) | <input checked="" type="checkbox"/> | Yes |
| Include FQS | <input type="checkbox"/> | No |
| Include CAD | <input type="checkbox"/> | No |
| Include Specialty DWG | <input type="checkbox"/> | No |
| Include Energy Audit | <input type="checkbox"/> | No |
| Include DSG | <input type="checkbox"/> | No |
| Interested in Rebate Opportunity | <input checked="" type="checkbox"/> | Yes |

- When customer has a project and is interested in rebates, sales should include that in their original department request by toggling 'Interested in Rebate Opportunity'.
- Rebate team will then:
 - Look into the scope of the project and gather any missing information
 - Reach out to the utility company to research available rebates
 - ✓ If project can be incentivized, we will then convert the department request and create the energy record
 - ✓ If the project cannot be incentivized, we will cancel the department request

Rebate Management Process Overview



What information is needed from you and your team to get started?

- Most recent utility bill
- Site address
- Customer contact information
- W9
- Square footage of site/Store Layout
- Scope of project (often provided by project manager or sales representative)
- Quotes for project (material and install)
- Signed Rebate Management Agreement
- Cost Estimate
- LOA



What types of projects are eligible for rebates?

- LED upgrades
- ECM Case Evap Fan motors
- Walk-in cooler/freezer evaporator fans
- Fan motor controls
- Antisweat Heaters and Controllers
- High Efficiency Freezer/Cooler Doors.
- Night curtains
- Case Door Retrofits (Medium and low temp)
- Door gaskets and strip curtains
- Parallel Rack and Protocol systems
- New Cases and Case Replacements
- Remodels
- New construction
- Reach inn Replacements
- VFD
- Carbon Credentials(New)



**If it saves ENERGY...
there's a REBATE for
THAT!**



Available Segments Include:



Agriculture



Appliances & Electronics



Combined Heat and Power



Commercial Lighting



Custom Equipment



HVAC



Instant Discounts



Solar



Food Service



Facility Audit Incentive

Rebates are typically offered in two forms:

Prescriptive

- LED case lighting
- Occupancy sensors
- Replacement cases
- Case Doors
- EC Motors
- Night covers
- Strip curtains
- Door gaskets
- Auto closers
- Anti sweat controls
- Floating head and suction pressure

Custom

- Offered when a project earns savings, but prescriptive rebate isn't available
- Often determined by a set \$/kWh saved
- Requires savings calculations, measurement, verification



Case Comparisons

- Baseline vs Proposed
- New Stores Replacements/Re-Models
- Competitive Comparisons
- Door Retrofits
- Existing vs Proposed

Salesperson Competitive Request Form

| | | | | | | | | | | | | | | | | | | | |
|------------------------|------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Date Submitted | | | | | | | | | | | | | | | | | | | |
| Date Needed | | | | | | | | | | | | | | | | | | | |
| Requestor's Name | | | | | | | | | | | | | | | | | | | |
| Customer Name | | | | | | | | | | | | | | | | | | | |
| Customer Street | | | | | | | | | | | | | | | | | | | |
| Customer City/Zip | | | | | | | | | | | | | | | | | | | |
| Customer State | | | | | | | | | | | | | | | | | | | |
| Comparison Type | | | | | | | | | | | | | | | | | | | |
| # Hours Case Lights On | | | | | | | | | | | | | | | | | | | |
| Local Electr. Cost | #N/A | *If you do not want to use the commercial avg. cost of electricity by state for your comparison, input the appropriate \$/kWh here → | | | | | | | | | | | | | | | | | |



| | Manufacturer | Application | Model | Length (dbs or feet) | Sill Height (if applicable) | Type of Refrigeration | Type of Defrost | Doors? (Y/N) | Type | Vertical Lamps? (Y/N) | Type | Canopy Lamps? (Y/N) | # Rows | Type | Shelf Lamps? (Y/N) | # Rows | Type | Rail Lamps? (Y/N) | Type | Lighting Sensor? (Y/N) | |
|----------|--------------|-------------|-------|----------------------|-----------------------------|-----------------------|-----------------|--------------|------|-----------------------|------|---------------------|--------|------|--------------------|--------|------|-------------------|------|------------------------|--|
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |
| Baseline | | | | | | | | | | | | | | | | | | | | | |
| Proposed | | | | | | | | | | | | | | | | | | | | | |

Insert Rows for Additional Lineups

Click to Compare Three Models

Undo Compare 3 Models

➤ What is "Case Comparison" & How is it used?



What Information Do The Salesperson provide on the request form

- | | |
|--|---|
| <ul style="list-style-type: none"> • General Info <ul style="list-style-type: none"> - Date comparison is needed by - Customer name/address <ul style="list-style-type: none"> • State provided prepopulates the average commercial kWh price • Can be overridden - Comparison type - # of hours case lamps are ON | <ul style="list-style-type: none"> • Lineup Info (Baseline, Proposed) <ul style="list-style-type: none"> - Manufacturer/Model/Length - Type of refrigeration - Type of defrost - Door type - Lighting configuration - Type of motors - Night curtains, lighting controls, etc |
|--|---|




Analysis Overview

| | |
|---|--|
| Date: | 7/7/2023 |
| Customer: | Jessica Moore, Freedom Line Up E-Grocery |
| Summary from Models on the Case Worksheet | |


X
Case EA FL

| Comparison | Mfg | Model | Description | Annual Operating Cost / Length of Line-Up | Line Up Length in Ft. | KWH/Year/Line up | Watts / Length of Line-Up/Yr | Usable Cube cuft / ft | Usable Cube cuft / line up | Facings sqft / ft | Facings sqft / line up | Annual Operating Cost / Usable Cubic | Annual Operating Cost / Sq Ft of Facings |
|------------|--------------|------------------|--|---|-----------------------|------------------|------------------------------|-----------------------|----------------------------|-------------------|------------------------|--------------------------------------|--|
| Proposed | Hussmann | RFL4-4drs | Freedom Line LT 4 door ReachIN, Innovator 1 doors with DASH control, Conventional Refrigeration (Freedom), Electric defrost, ECM motors(packout for 24" shelves vs 26" shelves included below) | \$1,312 | 4.000 | 8202.676 | 8202676.013 | 9.178 | 36.714 | 5.207 | 20.829 | \$35.75 | \$63.01 |
| Proposed | Hussmann | RFLM4-4 drs | FF, Freedom Reach-in, with plug in Top Mount Refrigeration, Innov-1 doors, Electric Defrost, with Condensate Pan Heater & Pump, Conventional Refrigeration | \$1,314 | 4.000 | 8211.231 | 8211231.049 | 10.908 | 43.632 | 5.208 | 20.832 | \$30.11 | \$63.07 |
| Baseline | Zero Zone | RVLC304-4 drs | Reach-In Merchandiser for Ice Cream with door, Conventional Refrigeration, Electric defrost, ECM fan. | \$1,561 | 4.000 | 9754.019 | 9754019.361 | 11.449 | 45.796 | 5.313 | 21.252 | \$34.08 | \$73.44 |
| Baseline | Masterbilt | BEL-4-30SC-4 drs | Low Temp Semi-Self Contained Endless Glass Door Merchandiser for Frozen Foods, Conventional Refrigeration, Electric Defrost, ECM Fan Motors | \$2,327 | 4.000 | 14541.487 | 14541487.301 | 11.144 | 44.576 | 5.450 | 21.800 | \$52.19 | \$106.73 |
| Baseline | Kysor Warren | Valzer KW4-4 drs | Low temperature Reach In self ontained Merchandiser for FF App, Conv. Refrigeration, Offtime defrost, ECM Fan Motor. | \$3,071 | 4.000 | 19193.175 | 19193175.379 | | | | | | |
| Baseline | Hill Phoenix | JNRZHS44-4 drs | High narrow Reach-in Self Contained Merchandiser with ELMD Doors for Frozen Foods, Conventional Refrigeration, Hot gas Defrost, ECM Fan Motors | \$2,009 | 4.000 | 12556.000 | ***** | | | | | | |



| | Summer Peak | Summer off Peak | Non-Summer Peak | Non-Summer off Peak | Summer Peak Demand kW | Total kWh | |
|------------------|-------------|-----------------|-----------------|---------------------|-----------------------|-----------|---------|
| % | 0.172603 | 0.161644 | 0.343151 | 0.322603 | | 1 | |
| Assumed Baseline | 88.25 | 82.65 | 175.45 | 164.95 | 0.06 | 511.30 | 511.36 |
| Proposed | 70.34 | 65.88 | 139.85 | 131.47 | 0.05 | 407.54 | 407.58 |
| Assumed Baseline | 44.97 | 42.11 | 89.40 | 84.04 | 0.03 | 260.52 | 260.55 |
| Proposed | 35.81 | 33.54 | 71.20 | 66.94 | 0.02 | 207.50 | 207.52 |
| Assumed Baseline | 528.13 | 494.59 | 1049.97 | 987.09 | 0.35 | 3059.78 | 3060.13 |
| Proposed | 129.02 | 120.83 | 256.51 | 241.15 | 0.09 | 747.50 | 747.59 |
| Assumed Baseline | 48.76 | 45.66 | 96.93 | 91.13 | 0.03 | 282.48 | 282.51 |
| Proposed | 51.50 | 48.23 | 102.39 | 96.26 | 0.03 | 298.38 | 298.41 |
| Assumed Baseline | 48.76 | 45.66 | 96.93 | 91.13 | 0.03 | 282.48 | 282.51 |
| Proposed | 35.81 | 33.54 | 71.20 | 66.94 | 0.02 | 207.50 | 207.52 |

Peak demand reduction
Rebates Analysis



| | Summer Peak | Summer off Peak | Non-Summer Peak | Non-Summer off Peak | Summer Peak | Total kWh | |
|------------------|-------------|-----------------|-----------------|---------------------|-------------|-----------|---------|
| Proposed | 322.49 | 302.02 | 641.15 | 602.76 | 0.21 | 1868.41 | 1868.63 |
| Assumed Baseline | 758.86 | 710.68 | 1508.68 | 1418.34 | 0.50 | 4396.56 | 4397.06 |
| Savings | 436.36 | 408.66 | 867.53 | 815.59 | 0.29 | 2528.14 | 2528.43 |

X
Matt B vs P

System EA

- Multiple CU's Vs Racks/Protocols
- Annual Energy Usage
- Existing Rack Vs Proposed Protocols
- Old Racks Vs New Racks
- Bin Analysis/Performance analysis

| System EA/System Energy Consumption Request Form | |
|--|---|
| Date Submitted | |
| Date Needed | |
| Requestor's Name | |
| Customer Name | |
| Store | |
| Store City Zip | |
| Store State or Province | |
| Comparison Type | |
| VOLTAGE | AMBIENT TEMP |
| Hours Store Lights On | |
| Local Electr. Cost | If you do not want to use the commercial avg. cost of electricity by state for your comparison, input the appropriate \$/kWh here 0.105 \$/kWh |

EMAIL COMPLETED FORM TO:
rebates@hussmann.com

Insert Rows for additional lineups

| | |
|-------|---|
| What | System Energy Comparison (Bin Analysis) |
| Who | Requested by Salesperson/Channel Partner from Application Engineer |
| How | Submit a request for system energy comparison through CRM; include all relevant system info for comparison (purposes, refrigeration schedules, etc) |
| Where | Submitted through CRM |
| When | Comparing energy of existing system to proposed, two proposed system, or for new construction |
| Why | Determine annual energy savings, project paybacks, REBATES! |

| SSYS | System Description | Unit Type | Compressor Type | Compressor/CU Model | Required Load/Capacity MBH | Operating Temperature | Group | Refrigerant | Type of Refrigeration | Design TD °F | Condenser type | Coold.Method |
|------|--------------------|-----------|-----------------|---------------------|----------------------------|-----------------------|-------|-------------|-----------------------|--------------|----------------|--------------|
| P | | | | | | | | | | | | |
| r | | | | | | | | | | | | |
| o | | | | | | | | | | | | |
| p | | | | | | | | | | | | |
| o | | | | | | | | | | | | |
| s | | | | | | | | | | | | |
| e | | | | | | | | | | | | |
| d | | | | | | | | | | | | |
| B | | | | | | | | | | | | |
| a | | | | | | | | | | | | |
| s | | | | | | | | | | | | |
| e | | | | | | | | | | | | |
| i | | | | | | | | | | | | |
| l | | | | | | | | | | | | |
| i | | | | | | | | | | | | |
| a | | | | | | | | | | | | |
| c | | | | | | | | | | | | |

| REFRIGERATOR / UNIT COOLER | | | | | | | | | | |
|----------------------------|-------|------------------|---------------------------|-------------------------|------------|---------|---------------|----------|----------|--|
| UNIT LTR | SYS # | SIZE | MODEL | DESCRIPTION | DISCH TEMP | CAP MBH | MID EVAP TEMP | DEF TYPE | DEF TERM | |
| | 1 | 400 SQFT | 4)KRD26A-089-TDB | 12 DOOR COOLER #2 | 35 | 29.40 | 25 | OT | TIME | |
| | 2 | | | FUTURE | | | | | | |
| | 3 | 10 X 9 X 8H | 1)KRD26A-089-TDB | WALK IN KITCHEN COOLER | 35 | 6.40 | 25 | OT | TIME | |
| | 4 | 8' center/2 ends | IM-04-EN4-R / IM-04-CN4-R | ISLAND XPRS | | 13.56 | 21 | OT | TIME | |
| | AM | | | | | 49.36 | 18 | | | |
| | 7 | 3" X 9'6" X 9H | 1)KRD16E-045-TDAA | 1 DOOR WALK IN FREEZER | -5 | 5.80 | -13 | EL | DIG | |
| | 8 | 10' X 10' X 8' | 1)KRD34E-111-TDAA | WALK IN KITCHEN FREEZER | -5 | 7.70 | -13 | | | |
| | 9 | 250 SQ FT | 3)JLHD34E-100-TDAA | 6 DOOR BEER CAVE | 28 | 22.50 | 20 | | | |
| | 10 | | | | | | | | | |
| | AL | | | | | 36.00 | -16 | | | |

← Input Info




Input

| | UNIT A | OPAH04TK | PROTOAIRE MC 4F4R |
|--------------------|----------|----------|-------------------|
| UNIT SPECS | 208/3/60 | R448A | Proto-aire |
| SUCTION GROUP | AM | AM | AL |
| COMPRESSOR | ZBD30KCE | ZB26KCE | ZF15K4E |
| COMP QUANTITY | 1 | 1 | 1 |
| DEW SUCTION TEMP | 22 | 22 | -12 |
| CAPACITY (BTUH) | 30,898 | 25,768 | 18,451 |
| POWER (KW) | 3.86 | 3.48 | 4.64 |
| HEAT OF REJ (BTUH) | 44,069 | 37,648 | 34,291 |
| COMPRESSOR RLA | 14.10 | 11.90 | 17.00 |
| OIL REGULATOR | | | |

| Fine Fare Mkt 3680 East Tremont Ave, Bronx, NY | | | |
|--|--------------|--------|-------------|
| PROPOSED PROTOCOL | | | |
| | Suction Temp | LOAD | COMPRESSORS |
| A1 | -23 | 58660 | ZFD25KVE |
| | | | ZF28KVE |
| | | | |
| A2 | 18 | 181870 | ZBD57KCE |
| | | | ZB48KCE |
| | | | ZB48KCE |
| | | | ZB48KCE |
| B | 25 | 279780 | ZBD45KCE |
| | | | ZB45KCE |
| | | | ZB45KCE |
| | | | ZB45KCE |
| | | | ZB45KCE |
| | | 520310 | |
| ASSUMED BASELINE - CU'S | | | |
| | Suction Temp | LOAD | COMPRESSORS |
| CU1 | -20 | 29600 | 3DB3F33KE |
| CU2 | -20 | 29070 | 3DB3F33KE |
| CU3 | 20 | 60080 | 3DA3R10ME |
| CU4 | 20 | 60710 | 3DA3R10ME |
| CU5 | 20 | 61070 | 3DA3R10ME |
| CU6 | 25 | 88620 | 3DB3R12ME |
| CU7 | 25 | 103680 | 3DS3R17ME |
| CU8 | 25 | 87480 | 3DB3R12ME |
| | | 520310 | |

| Overview | | | | | | | | | | |
|--|-----|-------------|----------|--------------|--|---------------|------------------------|-------------|-----------|--------------|
| NEW YORK/LA GUARDIA, NY | | | | | | | | | | |
| Fine Fare Mkt 3680 East Tremont Ave, Bronx, NY | | | | | | | | | Prepared: | 7/17/2023 |
| BASELINE CONDENSING UNITS | | | | | | \$/ku | NEW DESIGN LOADS WRACK | | | |
| | | | | | | \$ 0.11 | | | | |
| Suction Group | SST | LOAD BTU/HR | KWHR/YR | \$/YR | | Suction Group | SST | LOAD BTU/HR | KWHR/YR | \$/YR |
| CU1 | -20 | 29600 | 37,653.1 | \$ 3,953.57 | | A1 | -23 | 58660 | 62,528.0 | \$ 6,670.44 |
| CU2 | -20 | 29070 | 37,653.1 | \$ 3,953.57 | | A2 | 18 | 181870 | 100,848.0 | \$ 10,589.04 |
| CU3 | 20 | 60080 | 41,326.7 | \$ 4,339.30 | | B | 25 | 279780 | 131,854.6 | \$ 13,844.74 |
| CU4 | 20 | 60710 | 41,326.7 | \$ 4,339.30 | | | | | | |
| CU5 | 20 | 61070 | 45,918.5 | \$ 4,821.44 | | | | | | |
| CU6 | 25 | 88620 | 56,918.3 | \$ 5,976.42 | | | | | | |
| CU7 | 25 | 103680 | 80,465.8 | \$ 8,448.90 | | | | | | |
| CU8 | 25 | 87480 | 56,918.3 | \$ 5,976.42 | | | | | | |
| | | 520,310 | 398,180 | \$ 41,808.92 | | | | 520,310 | 296,231 | \$ 31,104.22 |



Microsoft Excel
ro-Enabled Works



Input



Assumption

Overview

Annual Energy Comparison

HANDY FOOD IGA#318 OTTAWA ,IL USA


| | | | | | | |
|---------|-------------------------|----------|---------------------|-------|------------------------|------------------|
| \$ 0.08 | COND METHOD: AIR COOLED | 208/3/60 | Horizontal Protocol | R448A | Prepared: Nikhil Patil | DATE: 05/02/2023 |
|---------|-------------------------|----------|---------------------|-------|------------------------|------------------|

Proposed Protocol Vs Baseline CU's

| Proposed Protocol | | | | | | | | \$/KW | Semi-Hermetic - CU's | | | | | | | |
|-------------------|---------------|-------------|-----|------------|------------------|----------------------|--------------------|---------|----------------------|-------------|---------------|-------------------|-------------|----------------------|------------------|--------------------|
| | | | | | | | | \$ 0.08 | | | | | | | | |
| Unit | Suction Group | Refrigerant | SST | COMPRESSOR | LOAD BTU/HR | Bin Energy KWH/HR/YR | \$/YR | | Suction Group | Refrigerant | SST | COMPRESSOR | LOAD BTU/HR | Bin Energy KWH/HR/YR | \$/YR | |
| AL | AL | R448A | -23 | ZFD25KVE | 139360 | 120830.00 | \$ 9,666.40 | | CUA | R-22 | 24 | 3DF3R15ME0TFC-800 | 92088 | 49038.00 | \$ 3,923.0 | |
| | | | | | | | | | CUB | MP-39/R-507 | -5 | LAHA-032E-TAC-800 | 18000 | 20367.00 | \$ 1,629.4 | |
| | | | | | | | | | CUC | R-22 | 45 | ZR47K3- TF5-935 | 32700 | 10636.00 | \$ 850.9 | |
| | | | | | | | | | CUD | R-507 | 0 | LALA-032E-TAC-800 | 22560 | 24521.00 | \$ 1,961.7 | |
| AH | AH | R448A | 24 | ZBD45KCE | 135560 | 50014.00 | \$ 4,001.12 | | CUE | R-404A | 0 | 3DA3F28KE-TFC | 31584 | 30073.00 | \$ 2,405.8 | |
| | | | | | | | | | CUF | R-507 | 0 | LAHA-032E-TAC-800 | 19200 | 20170.00 | \$ 1,613.6 | |
| | | | | | | | | | CUG | R-404A | 0 | LALA-032E-TAC(2) | 52800 | 57885.00 | \$ 4,630.8 | |
| | | | | | | | | | CUH | R-507 | -11 | 3DB3F33KE-TFC-800 | 21000 | 23620.00 | \$ 1,889.6 | |
| B | B | R448A | 16 | ZBD57KCE | 276340 | 133500.00 | \$ 10,680.00 | | CUI | R-507 | -19 | 3DS3F46KE-TFC-800 | 27940 | 35524.00 | \$ 2,841.9 | |
| | | | | | | | | | CUJ | R-12 | -11 | 9RS3-076A-TFC-800 | 25200 | 27334.00 | \$ 2,186.7 | |
| | | | | | | | | | CUK | R-404A | -11 | 3DA3-F28KE-TFC | 25200 | 28260.00 | \$ 2,260.8 | |
| | | | | | | | | | CUL | R-22 | 28 | 3DF3R15ME0TFC-800 | 9900 | 6036.00 | \$ 482.9 | |
| | | | | | | | | CUM | R-507A/R-502 | -25 | MRB1-050A-TFC | 22000 | 28328.00 | \$ 2,266.2 | | |
| | | | | | | | | CUN | R-437A/R-12 | 18 | MRF2-050A-TFC | 26800 | 20231.00 | \$ 1,618.5 | | |
| | | | | | | | | CUO | R-12 | 18 | 9RC1-0765-TFC | 53000 | 41343.00 | \$ 3,307.4 | | |
| | | | | | | | | CUP | MP-39/R-12 | 22 | 3RK1-031A-TAC | 15000 | 9889.00 | \$ 791.1 | | |
| | | | | | | | | CUQ | R-507A/R-502 | -18 | MRA2-050L-TFC | 20000 | 24997.00 | \$ 1,999.8 | | |
| | | | | | | | | CUR | R-507 | 22 | 2DD3R63KE-TFC | 36000 | 18929.00 | \$ 1,514.3 | | |
| | | | | | 551260.00 | 304344.00 | \$24,347.52 | | | | | | | 550972.00 | 477181.00 | \$38,174.48 |



EA HF Input



Performing Bin Energy Analysis

The screenshot shows the software interface for performing bin energy analysis. The interface is divided into three main sections: a left sidebar, a top navigation bar, and a main configuration area.

- Left Sidebar:** Contains 'Product Information', 'Annual Energy Analysis', and 'Tools'. An arrow points from 'Annual Energy Analysis' to the main configuration area.
- Top Navigation Bar:** Contains 'Project Details' and 'Analysis'. An arrow points from 'Project Details' to the main configuration area.
- Main Configuration Area:** Titled 'Annual Energy Analysis', it is divided into 'Design', 'Weather', and 'Project' tabs. The 'Design' tab is active, showing various design conditions:
 - Refrigerant: R-404A
 - Temp Range: Low Temp.
 - Dew Point: Dew Point, Mid Point
 - Evap. Temp. (°F): -25.0
 - Cond. Temp. (°F): 105.0
 - Minimum Cond. Temp. (°F): 70
 - Evap. Superheat (°F): 10.0
 - Return Gas Temp. (°F): 65.0
 - Liquid Subcooling: Required: Yes, No
 - Heat Sink: Variable, Constant
 - Fan: Evaporator (W): 0, Condenser (W): 0

- Open the PSS, Select “Annual Energy Analysis” on the toolbar on the left.
- The design conditions must be defined in the project details. Here you will select the location, Evaporating temperature, Condensing Temperature, Superheat, Return Gas, Subcooling, Refrigerant, System Capacity, Etc.
- Click “Project Details” on the toolbar on the left.

Analysis

Search Box - Compressors

Search Criteria

Application: Refrigeration Voltage: All Required Load Basis: Evaporator Compressor

Refrigerant: R-404A Phase: All

Temp. Range: All Frequency: All

Product Type: All Modulation: All

Availability: All Model:

Exclude Obsolete Models Rack Approved Models Only

Conditions

Const. Return Gas Temp. (°F) Const. Compressor Superheat (°F)

Low Point Mid Point

Evap. Temp. (°F): -25 Return Gas Temp. (°F): 65

Cond. Temp. (°F): 105 Total Subcooling (F): 0

Minimum Cond. Temp. (°F): 70 Evap. Superheat (°F): 10

Parameters Project Details Temp. Range Info. Definitions Search Reset

Compressor Selection : Step 1 Modulation Steps : Step 2

Compressors for AEER Calculation

| Qty. | Capacity Step Up | Capacity Step Down | Model | HP |
|------|------------------|--------------------|-------|----|
| | | | | |

Compressor Selection : Step 1 Modulation Steps : Step 2

Results

| Model | Refrig. | HP | Compressor Capacity (Btu/hr) | Compressor EER (Btu/Wh) | Evaporator Capacity (Btu/hr) | Evaporator EER (Btu/Wh) | Refrigerant Flow Rate (lb/hr) | Power (W) |
|----------------|---------|------|------------------------------|-------------------------|------------------------------|-------------------------|-------------------------------|-----------|
| 3DF3F40KE-T... | R-404A | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 716 | 7,600 |
| 3DF3F40KE-TFD | R-404A | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 716 | 7,600 |
| 3DF3F40KE-TFE | R-404A | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 716 | 7,600 |
| 3DF3F40KL-TFC | R-404A | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 716 | 7,600 |
| 3DF3F40KL-TFD | R-404A | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 716 | 7,600 |
| 3DF3F40KL-TFE | R-404A | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 716 | 7,600 |

1 of 6 Ready Reset Print [Click here to view Search Window](#)

Add Remove Save As Reset Project Details Ventil. Air Comp. Sel. Report

Compressors for AEER Calculation

| Qty. | Capacity Step Up | Capacity Step Down | Model | HP | Compressor Capacity (Btu/hr) | Compressor EER (Btu/Wh) | Evaporator Capacity (Btu/hr) | Evaporator EER (Btu/Wh) | Total Re |
|------|------------------|--------------------|---------------|------|------------------------------|-------------------------|------------------------------|-------------------------|----------|
| 1 | | | 3DF3F40KE-TFC | 6.00 | 40,200 | 5.29 | 28,500 | 3.75 | 4 |

- The Analysis window will open and the compressor search bar will appear. Input the Product type, Availability, Voltage, Phase, Frequency and Modulation. System Capability, Refrigerant, Return gas temperature etc. are automatically entered based on the user inputs in Project Details screen.
- You can also search by Model number or the beginning of a model number (i.e. 3DF3R15ME-TFD OR 3D).
- After the program finishes its search you can select the compressor you would like to use in your system. Select the compressor and click "Add".
- If you are adding multiple compressor with the same model, there is a drop down list located next to the compressor to increase the quantity.
- After selection click on the "Modulation step"

Report

Search Box - Compressors

Compressor Selection : Step 1 | Modulation Steps : Step 2 | Overall AEER : Step 3 | Summary - Annual Analysis : Step 4 | Compressor - Info : Step 5

Project Information
 Project Name: NA Contact: NA Location: Phoenix, AZ (USA)

Refrigerant: **R-404A** Annual (Hours): 8,760 Condenser Subcooling (F): 0 Design Load
 Design Comp. Load (Btu/hr): 100,000
 Dew Point Mid Point Return Gas Temp. (°F): 65 Natural Subcooling (F): 0 Comp. Capacity (Btu/hr): 40,200
 Evap. Temp. (°F): -25 Minimum Cond. Temp. (°F): 70 Mechanical Subcooling (F): 0 Condenser Subcooling Capacity (Btu/hr): 0
 Cond. Temp. (°F): 105 Condenser-Ambient ΔT (°F): 10 Overall AEER (Btu/Wh): 14.39 Natural Subcooling Capacity (Btu/hr): 0
 Evap. Superheat (°F): 10 Total Subcooling (F): 0 Mech. Subcooling Capacity (Btu/hr): 0
 Power Supply: 208-230V, 60Hz, 3 Ph Analysis Period: Full Year Load Profile: Fixed

| Ambient Air Temp. (°F) | Bin (Hours) | Cond. Temp. (°F) | Comp. Design Load (Btu/hr) | Comp. Capacity (Btu/hr) | Total Subcooling (F) | Mech. Subcooling Load (Btu/hr) | Comp. Power (W) | Actual Comp. Power (W) | Mech. Subcooler Comp. Capacity (Btu/hr) | Mech. Subcooler Comp. Power (W) | Actual Mech. Subcooler Power (W) | Total Power (W) |
|------------------------|-------------|------------------|----------------------------|-------------------------|----------------------|--------------------------------|-----------------|------------------------|---|---------------------------------|----------------------------------|-----------------|
| 25 | 6 | 70 | 100,000 | 54,000 | 0 | -- | 6,550 | 6,550 | -- | -- | -- | 6,550 |
| 30 | 25 | 70 | 100,000 | 54,000 | 0 | -- | 6,550 | 6,550 | -- | -- | -- | 6,550 |
| 35 | 165 | 70 | 100,000 | 54,000 | 0 | -- | 6,550 | 6,550 | -- | -- | -- | 6,550 |
| 40 | 249 | 70 | 100,000 | 54,000 | 0 | -- | 6,550 | 6,550 | -- | -- | -- | 6,550 |
| 45 | 486 | 70 | 100,000 | 54,000 | 0 | -- | 6,550 | 6,550 | -- | -- | -- | 6,550 |
| 50 | 677 | 70 | 100,000 | 54,000 | 0 | -- | 6,550 | 6,550 | -- | -- | -- | 6,550 |

Note: Overall AEER value includes AEER of selected Primary Compressors and Mechanical Subcooling Compressor (Selected in Steps 1 & 3) of this software.

Change Settings Report X Close

- After Reviewing the modulation steps and adjusting any of the settings you can then click the next tab "Overall AEER: step 3".
- This tab presents the report to include mechanical subcooling affets on the AEER to compute an overall AEER.
- This report can be printed by clicking "Report" and selecting the printer icon once the report is displayed on screen.

Annual Energy Savings

Search Box - Compressors

Compressor Selection : Step 1 | Modulation Steps : Step 2 | Overall AEER : Step 3 | **Summary - Annual Analysis : Step 4** | Compressor - Info : Step 5

Design Condition

Refrigerant: Total Subcooling (F):

Dew Point Mid Point Condenser Subcooling (F):

Evap. Temp. (°F): Natural Subcooling (F):

Cond. Temp. (°F): Mechanical Subcooling (F):

Evap. Superheat. (°F): Electricity Rate (\$/kWh) :

Condenser-Ambient ΔT (°F): Condenser Fan (W):

Return Gas Temp. (°F): Evaporator Fan (W):

Minimum Cond. Temp. (°F): Load Profile: [Fixed](#)

Analysis Period: Full Year

Design Comp. Load (Btu/hr): ...

Project Information

Project Name: NA Contact: NA Location: Phoenix, AZ (USA)

Output

Annual (Hours): Annual Energy Used by Primary Comp. (kWh):

Comp. Capacity (Btu/hr): Annual Energy Used by Mech. Subcooling Comp. (kWh):

Comp. Capacity Under Design (%): Annual Energy Used by Evap. Fan (kWh):

Overall AEER (Btu/Wh): Annual Energy Used by Cond. Fan (kWh):

Design Point

System Capacity (Btu/hr): Total Annual Energy Used (kWh):

System EER (Btu/Wh): Total Annual Energy Cost (\$):

Cond. Heat Rejection (Btu/hr):

| Capacity Delivered By | Evaporator(Btu/hr) | Compressor(Btu/hr) |
|---|--------------------|--------------------|
| Primary Compressors (@ 0F Total Subcooling) | 28,500 | 40,200 |
| Primary Compressors (@ 0F Subcooling) | 28,483 | 40,200 |
| Primary Compressors (@ 0F Condenser Subcooling) | | |
| Natural Subcooling (@ 0F) | 0 | 0 |

Note: Overall AEER value includes AEER of selected Primary Compressors and Mechanical Subcooling Compressor (Selected in Steps 1-3) of this software.

Selected: Primary Compressors
3DF3F40KE-TFC (1)

Selected: Mechanical Subcooling Compressors
NA

- The Next Tab **“Summary-Annual Analysis: Step 4”** Provides A Summary Of The Energy Analysis Including The Total Energy Used And Total Energy Cost.

- This Report Can Be Printed By Clicking **“Report”** And Selecting The Printer Icon Once The Report Is Displayed On Screen.

Compressor Information

Compressor Selection : Step 1 Modulation Steps : Step 2 Overall AEER : Step 3 Summary - Annual Analysis : Step 4 Compressor - Info : Step 5

Design Condition

| | | | |
|------------------------|----------------------|---------------------------------|-------------|
| Refrigerant: | R-404A Dew Pt. | Condenser Subcooling (F): | 0 |
| Power Supply: | 208-230V, 60Hz, 3 Ph | Natural Subcooling (F): | 0 |
| Evap. Temp. (°F): | -25 | Mechanical Subcooling (F): | 0 |
| Cond. Temp. (°F): | 105 | Minimum Condensing Temp. (°F): | 70 |
| Evap. Superheat (°F): | 10 | Design Comp. Load (Btu/hr) | 100,000 ... |
| Return Gas Temp. (°F): | 65 | Comp. Capacity (Btu/hr) | 40,200 |
| Total Subcooling (F): | 0 | Comp. Capacity Under Design (%) | -59.8 |

Project Information

| | |
|---------------|-------------------|
| Project Name: | NA |
| Contact: | NA |
| Location: | Phoenix, AZ (USA) |

| Compressor | Application | Comp. Cap. (Btu/hr) | Power (W) | Comp. EER (Btu/Wh) | Evap. Cap. (Btu/hr) | Evap. EER (Btu/Wh) | Cond. Heat Rejection (Btu/hr) | Subcooling Capacity (Btu/hr) | Mass Flow (lb/hr) | Current (Amps) | Mod |
|---------------|-------------|---------------------|-----------|--------------------|---------------------|--------------------|-------------------------------|------------------------------|-------------------|----------------|-----|
| 3DF3F40KE-TFC | Primary | 40,200 | 7,600 | 5.29 | 28,500 | 3.75 | 66,139 | 0 | 716 | 24.6 | |
| | Total | 40,200 | 7,600 | 5.29 | 28,500 | 3.75 | 66,139 | 0 | 716 | 24.6 | |

% Total Capacity of Primary Comp.: [Comp. Capacity / Design Comp. Load] x 100

Report  Close

- The Final Step “Compressor-Info:Step 5” Breaks Down The Analysis By The Individual Compressors.
- Select The “Report” Button For A Printable Report Showing Information Of Selected Compressors.
- If You Want To Change The Design Conditions, System Capacity, Refrigerant, Or Fan Use. You Will Need To Return To The Project Details And Start Over.

OFFLINE SUBMISSION-

Remodel Store **Aldi #74,PA** Applied for Cases & Systems



2021-2022
Business Program
Energy Solutions




Met Ed • Pennep • Penn Power • West Penn Power

https://www.firstenergycorp.com/save_energy/save_energy_pennsylvania.html

OFFLINE SUBMISSION-

Reach in replacement Store **Safeway #1566,AZ** Applied for Cases through Prescriptive and Custom measure.

RE: Your application is now complete - SAFEWAY INC #SBS_203789

 Pruitt, Crystal
To srpprocessing@resource-innovations.com
Cc Sharon.Kausal@srpnet.com; Kbenton@Resource-Innovations.com; [Vishwanath Patil, Nikhil](mailto:Vishwanath.Patil@Resource-Innovations.com)


[Click here to download pictures.](#) To help protect your privacy, Outlook prevented automatic download of some pictures in this message.

\$21,241.60 rebate approved for

April 1, 2023
is your estimated check arrival date*
*Check arrival dates are estimates only.

payment.
The check will be mailed to:

Hussmann Corporation
26372 Network Place
Chicago, IL 60673
N/A
N/A
N/A, N/A N/A

 Right-click or tap and hold

270,080 kWh



Microsoft Excel
Macro-Enabled Worksheet

ONLINE SUBMISSION-

<https://comedstndportal.anetrack.com/comedeestandportal/Home>


Final Application & Payment Process


After Installation:

- Install start & end dates provided to utility
- Send final customer itemized invoice(s) (verification for Utility)
- Sign & return Final Rebate Application
- Once Hussmann receives rebate check from Utility, we will process check to customer with report on full financial details.



Value Date: 03/27/2023 Program: 26372 - Chicago - HUSSMANN CORPORATION Batch Number: 608 Item Number: 8
Payment Serial Number: 4448834 Amount: USD 14,400.00 Entity Name: XCEL ENERGY

 Public Service Company of Colorado Wells Fargo Bank, N.A.
d/b/a Xcel Energy
1800 Larimer St.
Denver, CO 80202
800-895-4999



Date 03/15/23


0004448834
56-282
412
960001272i

\$14,400.00 USD

Pay FOURTEEN THOUSAND FOUR HUNDRED***** DOLLARS

VOID IF NOT CASHED IN 90 DAYS

To The Order Of HUSSMAN CO
C/O NIKHIL PATIL
26372 NETWORK PL
CHICAGO IL 60673-1263



THE FACE OF THIS DOCUMENT HAS A COLORED BACKGROUND ON WHITE PAPER AND A WATERMARK, HOLD AT AN ANGLE TO VIEW

⑈0004448834⑈ ⑆04 203824⑆960001272⑈ ⑆0001440000⑆

FAST FACTS about **Hussmann Rebate Management**

Rebates captured for: Refrigerated case and Overhead lighting LED upgrades, HVAC, EC motor retrofits, EcoVision door upgrades, Remodel Stores, New Stores, Protocol systems, Rack Systems, VFD, Oversized condensers, etc

Hussmann is an active participating partner in **over 40** utility Trade Ally networks across the country and Canada

Large Custom

&

Multisite projects

\$ 2M

Customer Rebates captured in 2022/23

\$ 3M

Customer Rebates captured YTD

233+

Rebate Applications submitted in 2019

Collaborated with **54 different utilities** in the United States and Canada to secure rebates for customers in 2022

Rebates are an **integral part** of the **TURN-KEY SOLUTION** provided by Hussmann

Rebates can be obtained for both New and Remodel stores

How Can You Help Customers Capture Rebates?

Contacts:

EMAIL US AT:

Rebates@Hussmann.com

314-501-8763

Nikhil Patil

Energy Rebate Analyst

Crystal Pruitt

Sales Effectiveness Specialist

Thank you!

