



ISHRAE
Position Paper
on
Indoor Environmental Quality

August 2015

Introduction

Indoor Environmental Quality (IEQ) refers to the quality of environment inside buildings that is determined by many factors, including indoor air quality (IAQ), thermal comfort, lighting quality, acoustic conditions as well as furniture and space layout. IEQ has an impact on health, comfort, safety, and productivity of building occupants.

In a good indoor environment, work efficiency of occupants gets enhanced, learning results are better among students and absenteeism is lower. This in-turn increases workplace productivity and test-scores in schools, which is supported by research.

Research has shown that the pollutants, often present in indoor air, have a clear link with productivity, sense of wellbeing and occupant health. In long term, they lead to health hazards like asthma, allergies, headaches and respiratory diseases. Furthermore, temperatures that are too high or too low, continuous high noise levels, or excessively bright or inadequate lighting level; increase the stress levels in the human body, thus creating health issues like sleep disorder, digestive problems, memory and concentration impairment.

ISHRAE is committed to increase awareness about importance of the Indoor Environmental Quality (IEQ) and its impacts on human health. It is important to highlight that emphasis on IEQ in building design and operation, need not be a detractor for energy savings in buildings. ISHRAE emphasizes the fact that design and operation of HVAC systems in buildings can significantly impact exposure of occupants to air pollution, thermal discomfort, visual discomfort and acoustic problems.

Indoor Air Quality

Indoor Air Quality (IAQ) is considered to be 'healthy' when the air does not contain contaminants in harmful concentrations and is acceptable when the majority of people feel satisfied. Exposure to hazardous airborne agents present in many indoor spaces causes adverse effects such as respiratory and cardiovascular diseases, allergy, and irritation of the respiratory tract and possibly lead to cancer [1]. That is why our responsibility is to provide healthy indoor environment for occupants [2]. We breathe about 12000 litres of air every day and it is vital for our health to make sure that the air we breathe is clean.

Indoor air pollution is the second highest killer in India and is linked to the outdoor air quality. Outdoor air pollution has a direct impact on indoor air quality. Cost of air pollution to society in 2010 was estimated at US\$ 0.5 trillion in India according to a recent study by the Organization for Economic Co-Operation and Development (OECD) [3]. Due to poor outdoor air quality in most cities in India, Indoor Air Quality (IAQ) cannot be improved merely by increasing the ventilation rate without proper ambient air particulate and gas filtration, as prescribed in several international standards [4-5-6].

Respirable Suspended Particulate Matter (RSPM) is one of the main ambient air pollutants. According to the database of Central Pollution Control Board (CPCB), Government of India [7], that includes RSPM levels of 124 Indian cities, 123 cities have $PM_{2.5}$ annual average level above WHO Air Quality Guideline level ($10 \mu\text{g}/\text{m}^3$) [8]. The International Agency for Research on Cancer (IARC) concluded in 2013 that ultra-fine particulate matter is carcinogenic to humans. If no action is taken to bring down the current RSPM levels, deaths from air pollution would increase by 20% to 30% in India [9].

Main sources of particulate matter in India are vehicle emissions, household cooking (especially cooking with biomass and frying), thermal power plants, biomass burning, construction work, unattended debris, fossil fuels (such as diesel) based power generators and various industrial processes.

In addition to RSPM, there are host of other pollutants that contribute towards deterioration of the ambient air quality. In many areas, Ozone (O_3), Sulphur dioxide (SO_2), Oxides of Nitrogen (NO_x), Hydrogen Sulphide (H_2S) and Lead (Pb) levels are also reported to be significantly higher as compared to international guidelines.

Carbon dioxide (CO₂) is neither an indoor air pollutant by itself nor a direct health risk in typical indoor concentrations (500-1200 ppm). However, high level of CO₂ may lead to drowsiness, headache or lower activity levels among occupants, and thus should be controlled. Since, measuring CO₂-level is relatively easy as compared to other pollutants, it is used as an indicator of ventilation efficiency.

Solvents, paints and other building materials as-well-as cleaning agents may release Volatile Organic Compounds (VOCs) into the indoor air. Emissions are typically high in newly finished interiors and reduce exponentially as it ages.

ISHRAE hold the view that most common indoor air quality problems are caused by inadequate ventilation and filtration, and improper air distribution. Correct design, material selection and proper maintenance of equipment can enhance IAQ. Undoubtedly, the HVAC industry is in a key position to improve the IAQ and positively impact human health in buildings.

Thermal Comfort

Thermal conditions within living and working environments play a critical role in influencing occupant comfort and wellbeing. Research has shown that along with air quality, thermal comfort is one of the critical variables influencing worker productivity [10]. In addition, a substantial part of operational energy in contemporary buildings is used to alleviate thermal discomfort. In India, cooling energy comprises 40-60% of the total energy used in air-conditioned buildings.

Predicted Mean Vote (PMV) model expressed as a function of air temperature, mean radiant temperature, air velocity, humidity, metabolic activity and clothing is widely used to predict thermal comfort in air-conditioned buildings. While the PMV model remains the basis for Western and European standards of thermal comfort [6, 11], these standards also refer the adaptive thermal comfort model to predict acceptable indoor thermal conditions.

Adaptive thermal comfort is the theory that suggests that indoor comfort is influenced by outdoor climate, and aspects such as connection to outdoors and control over the immediate environment allow occupants to adapt to a wider range of thermal conditions.

In the absence of a thermal comfort model specific to Indian conditions, the current practice is to adopt ASHRAE guidelines for air-conditioned building. However, a number of field studies in India suggest that the adaptive thermal comfort model could be a more relevant approach.

Central Building Research Institute (CBRI) in India has formulated an India specific thermal comfort assessment criteria termed as the Tropical Summer Index (TSI). Researchers have conducted thermal comfort surveys on a wide range of occupants in different types of buildings.

Following are major findings of these studies:

- Indian building occupants are more adaptive and tolerant of higher temperatures during summer conditions than predicted under the PMV model.
- Indians are found to be comfortable over a larger range of air velocity [12].
- In addition to temperature, and air velocity, high tolerance for humidity is also found especially, in warm and humid climatic zones [13]
- Adaptive models for thermal comfort for naturally ventilated and mixed mode commercial buildings that cover the five climate zones in India show Indian occupants to be more adaptive than would be predicted under the adaptive models derived for ASHRAE-55-2013 and EN

- There is up to 15% energy saving potential in buildings with use of adaptive approach in operation of air-conditioning systems through keeping floating thermostat set point in place of fixed set point [15, 16]

ISHRAE emphasizes that thermal adaptation of occupants is a very important aspect of building design and operation. Thermal comfort can be governed through various combinations of air velocity, humidity, air temperature, mean radiant temperature and by adjusting clothing. ISHRAE further suggests that metrics such as 'Effective Temperature' and 'Operative Temperature', that consider combined effect of above parameters, should be adopted as the basis of thermal comfort evaluation, rather than air temperature alone.

Humidity And Mould

Humidity in the occupied spaces affects the comfort of the occupants, corrosion of the building materials, electrostatic discharge, mould and mildew, bacteria and virus. Although human beings can tolerate a wide range of humidity conditions without the feeling of discomfort, very low humidity conditions cause dryness of skin and mucous membranes in the nose, throat and eyes while extreme humidity results in sweating and discomfort particularly at higher temperatures.

Moisture is the universal requirement for fungal growth; keeping it under control is critical to inhibit mildew and mould. Mildew grows on damp organic materials such as paper. Moulds can damage property and can spoil food. Certain moulds can be very pathogenic and cause disease. The health consequences are particularly significant in hospitals, but can impact users in all types of buildings.

Building construction materials used in India, are usually not airtight. Hence, use of proper vapour barriers on exterior walls can alleviate the condensation problem. Some HVAC components cause suction leading to negative pressure in the building. At such places, if the space interfaces with exterior wall, humid outside air gets in through cracks.

The condensate drain pans of air handling units, filters, duct work downstream of the cooling coil, drain from indoor units, are some places where fungal growth is commonly found. Limiting the drift of condensate water and restricting the relative humidity in the ductwork and the use of well-maintained filters can limit the growth of moulds in the duct work.

ISHRAE considers that the problem of humidity driven mould is a serious health risk in buildings. This problem is having greater significance in air-conditioned buildings as compared to naturally ventilated buildings

Lighting Conditions

Good lighting provides adequate level of task visibility without causing discomfort, and creates an attractive and interesting visual environment while achieving energy efficiency, providing positive impact on health, productivity and wellbeing of occupants. Research shows that light has significant impact on many bodily functions, including the nervous system, circadian rhythms, pituitary gland, endocrine system, pineal gland and alertness, which are affected by different wavelengths of light [17].

In a hospital environment, it is found that patients exposed to an increased intensity of sunlight experienced less perceived stress, marginally less pain, took 22% less analgesic medication per hour, and had 21% less pain medication costs [18].

Increased lighting can be beneficial to elderly people with deteriorating vision. An environment that is easy and comfortable helps to promote an elderly person's sense of competence and independence, increase safety, promote better health and add to quality of life. Low lighting levels may lead to tripping and falling due to lower visibility of hazards such as unexpected steps, or sudden changes in floor surfaces etc.

Daylighting has been associated with higher productivity, lower absenteeism, fewer errors or defects in products, positive attitudes, reduced fatigue, and reduced eyestrain[17]. One of the important psychological aspects from daylighting is the connection with the outdoor environment. The spectral requirements of the

circadian system are also more closely matched by daylight than by most artificial light sources [19]. Tapping daylight does not only reduce the need of artificial lighting but also reduce cooling load. However heat gain and glare related issues need to be addressed with use of control strategies

ISHRAE strongly supports an integrated approach in lighting design (daylighting and artificial lighting) considering all the design factors such as orientation, form of the building, window sizes and placement, selection of glass type, shading devices, skylight design, interior furniture layout, construction materials and finishes. One of the major shifts observed in work spaces is a shift from horizontal work planes (desks and paper focus) to vertical work planes (computer screens). Standards also need to ensure that they avoid glare on vertical planes, and related issues as well.

Acoustic Environment

Noise is considered as unwanted sound. Noise can affect productivity and health in commercial and residential buildings. Loud noise can cause hearing loss, stress, alter sleep patterns, and affect heart rate based on other IEQ co-factors. However, sound need not be loud to become unwanted and annoying.

Noise can mask important sounds and disrupt communication between individuals in a variety of settings. Noise can disrupt face-to-face and telephone conversation, and the enjoyment of radio and television. Interference with communication has proved to be one of the most important components of noise-related annoyance. It can cause fatigue and vocal strain in those who need to communicate in spite of the noise.

Night noise management is especially important in residential buildings, hospitals and hotels located near main roads. As per research, 40 dB is equivalent to the Lowest-Observed-Adverse-Effect Level (LOAEL) for night noise. Above 55 dB the cardiovascular effects become the major public health concern, which are likely to be less dependent on the nature of the noise [20].

Noise is also a major problem in open-plan-offices and call centers. Speech is the most disturbing noise that prevents people to concentrate on their work. Studies have shown that speech impairs the performance of cognitively demanding tasks, e.g. verbal and memory recall tasks. A good background noise level in open plan office is 40dB, which is usually generated by ventilation systems or active background noise generation which may also be used if required.

ISHRAE holds the view that noise level and acoustic privacy should be controlled by acoustical means, i.e. by incorporating acoustic considerations in building design, adding sufficient amount of sound absorption material to the space and making sure that the background noise level is appropriate.

Evaluating IEQ – Measurement and Occupant Feedback

Traditionally the evaluation of the indoor environmental quality of buildings has focussed on the measurements of the physical attributes of the environment. The attributes can be assessed via site measurements taken over the course of one day or on the basis of long term monitoring from BMS systems or data loggers, using approved measurement protocols and instrumentation with the required resolution and accuracy. This approach is used to verify whether the physical attributes satisfy stipulated targets.

It should be recognised that physical measurements taken in isolation do not provide the full picture of occupant experience. While the measurement of physical attributes yields quantitative data, it can restrict the focus to easily measurable parameters often ignoring combined effects of multiple variables affecting thermal visual and acoustic comfort. Aspects such as acoustic privacy, and local effects of comfort (drafts, temperature variation, stuffiness, glare and odours), are also difficult to measure and do not get picked up without direct feedback from occupants.

Researchers demonstrated the importance of understanding users' experience as a measure of the effectiveness of the indoor environment [21, 22]. Qualitative survey instruments such as Building Use Studies, CBE Occupant *Indoor Environmental Quality (IEQ)* Survey and BOSSA are carefully designed to capture occupant feedback and satisfaction regarding building design, overall comfort, thermal comfort and air quality, lighting, noise, privacy, space usage, design, perceived health and productivity by "asking the occupant" [23, 24]. The survey feedback is used for diagnostic purposes as well as for benchmarking buildings in relation to one another as seen in post occupancy evaluation (POE) studies of individual and large sets of buildings [25, 26]. Following an increased recognition of the value of this approach, these POE survey tools are now included in rating IEQ in tools such as LEED, WELL and NABERS Indoor Environmental Rating Tool.

Energy and IEQ

ISHRAE emphasizes that IEQ considerations need not be a constraint for energy efficiency in buildings. An integrated design approach that considers BOTH indoor environmental quality and energy is crucial for the long term sustainability of buildings in India. Post occupancy evaluations of successful green buildings indicate they can deliver low energy as well as high indoor environmental quality and comfort for its occupants. Typically such buildings harness low-energy attributes that people like such as natural light, fresh air, connection with outdoor and an adaptive approach to thermal comfort, coupled with low VOC finishes and a user responsive approach to their operation and management.

ISHRAE recognises that 80% of electricity produced in India comes from fossil fuel based thermal power plants and any additional energy consumption will result in increase in greenhouse gas emissions. However, poorly conceived strategies for energy efficiency can create detrimental effects on IEQ. A case in point is the Sick Building Syndrome that arose as a consequence of reduced outdoor air ventilation rates in European buildings in the late 70's and 80's following the oil crisis. On the other hand in some extreme cases (such as extreme outdoor air pollution) where additional energy consumption cannot be avoided for meeting IEQ requirements, a balanced approach between increment in energy consumption and increased pollution load should be adopted.

Ishrae's Position

- Air pollution is one of the biggest environmental health risks in India and needs to be addressed by all stakeholders i.e. people, government and industry. Outdoor and indoor air quality needs to be improved urgently. As the indoor air quality improvements are easier to implement, the focus shall be on making buildings healthier for its users.
- Controlling contaminants at source is the most important activity to improve air quality. Purification of outdoor air before being supplied into the building is important along with material and equipment selection.
- Good construction and installation practices, low emission operation and maintenance practices are required in order to improve IAQ.
- Where outdoor air quality does not meet national AQI, emphasis should be given to ventilation and filtration design.
- An Adaptive Thermal Comfort approach needs to be followed in building design and operation. There should be avenues to implement adaptive thermal comfort standards.
- Operative and effective temperature based approach should be used to evaluate thermal environment that covers combined effect of air temperature, humidity, air velocity, radiant temperature, clothing and activity.

- Higher air velocity offers opportunity to maintain thermal comfort at higher air temperature.
- Humidity control measures should be implemented as per purpose for which building is occupied.
- Since mould and mildew proliferate when humidity goes unchecked and can be potentially hazardous for the health of the inhabitants, both low and high humidity need to be avoided.
- Focus in building design and operation shall be in vapour barrier treatment and avoiding negative room pressures apart from controlling humidity to prevent mould and mildew.
- Lighting standards need to be improved for providing additional guidance on appropriate selection of the spectrum for particular task and environment.
- Noise mitigation measures are required to limit the impact of noise to human health. This requires standardized noise levels both generated inside the building and external noise transferred via building envelope.
- Building design decisions for maintaining IEQ from health perspective should be inter-dependent with HVAC system sizing and operating energy consumption.
- ISHRAE recognises the value of gaining direct feedback from occupants to gauge occupant satisfaction and experience of IEQ aspects to augment physical measurements of IEQ attributes and recommends its inclusion for Post Occupancy Evaluation studies.

Conclusion / Recommendations

ISHRAE has recognized that the issue of indoor environment quality, including thermal comfort, lighting comfort, acoustic comfort and indoor air quality, needs urgent attention of designers, operators and building owners. It also identifies necessity of extensive field studies covering different building types, locations, age groups, work profiles. Such studies should be conducted following international protocols for measurements of IEQ parameters, a transparent methodology of analysis and finally validation of research findings. Further, requirement of linking several standards, viz. thermal comfort, indoor air quality, daylighting and acoustic standards, in Indian context may also be looked so that a comprehensive IEQ classification/standard can be formed for Indian buildings keeping energy efficiency under active consideration.

ISHRAE needs to increase the general awareness of health effects of poor IEQ and relevant solutions to improve it among public and building professionals.

Additional research is required to determine the relative significance of the visual and health implications of typical light exposures on circadian, neuroendocrine, and neurobehavioral patterns.

Integrated building design needs to be promoted in the building community to ensure that maximum benefit is taken from all IEQ parameters, especially daylighting and artificial lighting to meet the holistic needs.

A common IEQ standard and classification criteria for buildings is required in India to address above mentioned issues comprehensively. This is necessary for allowing users, owners and designers to make well-informed decision

ISHRAE (Indian Society of Heating, Refrigerating & Air Conditioning Engineers) has formed a national level committee, focused on Indoor Environment Quality issues in India. Members of this committee have multi-disciplinary knowledge of different aspects of IEQ both in India and abroad. Focus of this committee is on developing India specific research/technical reports and recommendations for IEQ management covering indoor air quality, thermal comfort, lighting and acoustic conditions, while ensuring proper use of energy resources. ISHRAE also endorses importance of past and ongoing research efforts related to IEQ in Indian institutes and invite more and more such organizations/individuals to take part in this endeavour.

References

1. Moran A.E., Forouzanfar M.H., Roth G.A., Mensah G.A., Ezzati M., Murray C.J.L., Naghavi M., 2014. Temporal trends in ischemic heart disease mortality in 21 world regions, 1980-2010: The Global Burden of Disease 2010 Study.
(<http://www.ncbi.nlm.nih.gov/pmc/articles/PMC4181359/pdf/nihms-625986.pdf>; accessed on July 24, 2015)
2. Report on a WHO meeting, 2000. The Right to Healthy Indoor Air.
(http://www.euro.who.int/__data/assets/pdf_file/0019/117316/E69828.pdf; accessed on July 20, 2015)
3. OECD Report, 2014. The Cost of Air Pollution: Health impacts of road transport
(<http://dx.doi.org/10.1787/9789264210448-en>; accessed on July 20, 2015)
4. ANSI/ASHRAE Standard 62.1-2013, Ventilation for Acceptable Indoor Air Quality.
5. ANSI/ASHRAE Standard 62.2-2013, Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings.
6. EN Standard 15251:2007, Indoor Environmental Input Parameters for Design and Assessment of Energy Performance of Buildings Addressing Indoor Air Quality, Thermal Environment, Lighting and Acoustics.
7. CPCB, Environmental Data Bank, Central Pollution Control Board, Government of India.
(<http://www.cpcb.nic.in>; accessed on July 24, 2015)
8. UNEP Year Book, 2014. Air Pollution: World's Worst Environmental Health Risk.
(<http://www.unep.org/yearbook/2014/PDF/chapt7.pdf>; accessed on July 24, 2015)
9. IARC and WHO, 2013. Outdoor air pollution a leading environmental cause of cancer deaths, press release no. 221.
(http://www.iarc.fr/en/media-centre/iarcnews/pdf/pr221_E.pdf; accessed on July 20, 2015)
10. Leaman A., Bordass W., 1999. Productivity in buildings: the 'killer' variables. Building Research & Information 27(1), 4–19.
11. ANSI/ASHRAE Standard 55–2013 Thermal Environmental Conditions for Human Occupancy
12. Dhaka S., Mathur J., Brager G., Honnekari A., 2015. Assessment of thermal environmental conditions and quantification of thermal adaptation in naturally ventilated buildings in composite climate of India. Building and Environment 86, 17–28.
13. Indraganti M., Ooka R., Rijal H.B., Brager G., 2014. Adaptive model of thermal comfort for offices in hot and humid climates of India. Building and Environment 74, 39-53.
14. Manu S., Shukla Y., Rawal R., de Dear R., Thomas L., 2014. India Model for Adaptive Comfort (IMAC) (CEPT University; Ahmedabad India). Submitted to Ministry of New and Renewable Energy, Govt. of India and Shakti Sustainable Energy Foundation.
15. Dhaka S., Mathur J., Garg V., 2012. Combined effect of energy efficiency measures and thermal adaptation on air conditioned building in warm climatic conditions of India. Energy and Buildings 55, 351-360..
16. Thomas L.E., 2014. Shifting the norm – towards effective mixed mode buildings. 30th International PLEA Conference Sustainable Habitat For Developing Societies Choosing The Way Forward - Proceedings, CEPT UNIVERSITY PRESS, Ahmedabad, pp. 440-447.

17. Edwards L., Torcellini P., 2002. A Literature Review of the Effects of Natural Light on Building Occupants. NREL/TP-550-30769. Contract No. DE-AC36-99-GO10337 (<http://www.nrel.gov/docs/fy02osti/30769.pdf>; accessed on July 20, 2015)
18. Walch J.M., Rabin B.S., Day R., Williams J.N., Choi K., Kang J.D., 2005. The effect of sunlight on postoperative analgesic medication use: a prospective study of patients undergoing spinal surgery. *Psychosom. Med.* 67 (1), 156–163.
19. Rea, M.S., Figueiro, M.G., Bierman, A., Bullough, J.D, Circadian light, *J. Circadian Rhythms.* 8 (2010) 2.doi:10.1186/1740-3391-8-2
20. Vischer J.C., 1989. *Environmental Quality in Offices.* New York, Van Nostrand Reinhold.
21. Leaman A., Thomas L.E., Vandenberg M., 2007. 'Green' buildings: what Australian users are saying? *EcoLibrium(R)* 6(10), 22–30.
22. Leaman A., BordassB., 2001. Assessing Building Performance in Use 4: The Probe Occupant Surveys and their Implications. *Building Research and Information* 29 (2), 129–143.
23. BOSSA - The Building Occupants Survey System Australia (www.bossasystem.com/; accessed on July 20, 2015).
24. Zagreus L., Huizenga C., ArensE., Lehrer D., 2004. Listening to the Occupants: A Web-Based Indoor Environmental Quality Survey. *Indoor Air* 14 (Suppl. 8), 65–74.
25. Thomas L.E., 2010. Evaluating Design Strategies, Performance and Occupant Satisfaction: A Low Carbon Office Refurbishment. *Building Research and Information* 38 (6), 610–624.
26. CBE Occupant Indoor Environmental Quality (IEQ) Survey. (www.cbe.berkeley.edu/research/survey.htm; accessed on July 24, 2015).

Disclaimer:

ISHRAE's position is based on all referenced works with year of release as mentioned. Any revisions in the referenced works shall not be automatically deemed to be accepted by ISHRAE unless specifically confirmed or updated by ISHRAE.

In case of any differences between the referenced works and ISHRAE's position, user is requested to bring to the notice of these differences to ISHRAE's Technical Committee; however ISHRAE's position, where explicitly stated, shall apply.

About IEQ Committee Members

Ashish Rakheja is the Managing Director of AEON Consultants. He completed his graduation from REC Allahabad in mechanical engineering, followed by M.Tech in thermal engineering from IIT Delhi. He is Past President ISHRAE and ASHRAE India Chapter; Chairman, Technical Committee, IGBC; Chairman, Environment Committee, PHD CCI; Chairman, Green Building Committee at FSAI; Advisor, International Fenestration Forum; Committee Member for Uniform Mechanical Code of India under the aegis of IAPMO-USA; and serves on several other bodies. He has won Lifetime Achievement Awards from ISHRAE and ASHRAE India, Distinguished Service Award from ASHRAE, and various other awards. He has presented over 400 papers at international and domestic forums.

Dr. Jyotirmay Mathur is a Professor in mechanical engineering at Malaviya National Institute of Technology, Jaipur. His research interests are energy efficiency, low energy cooling systems and energy policy modeling. He has 23 years of experience in teaching and research. His current activities include studies on adaptive thermal comfort, radiant cooling systems, and energy codes and standards.

Maija Virta has over 25 years of experience in construction and HVAC industry spread over the globe. She specialises in sustainable building policies and technology, and has been involved in developing user-centric IEQ measurement, verification and post-occupancy evaluation processes. Prior to moving to India, Maija was the CEO of Green Building Council of Finland. She has authored many books and publications, and presented papers and lectures in forums stretching across three continents.

B. Gautham Baliga is Director at OPAL HVAC Engineers Pvt. Ltd., which specialises in design-build of pharmaceutical, healthcare and industrial HVAC systems. He has been involved in projects with special focus on humidity issues. He is a mechanical engineer from IIT Kharagpur and worked with Voltas for 8 years. He is on the Editorial Board of *Air Conditioning and Refrigeration Journal*, and is a member of ISHRAE Technical Committee, Chair of Certifications Committee, and ISHRAE Distinguished Lecturer.

Leena Thomas is Associate Professor, Strand Leader in Environmental Studies at the School of Architecture, University of Technology, Sydney. Her research focuses on building performance, sustainable architecture, IEQ and post-occupancy evaluation with particular expertise in Indian and Australian contexts. Her expertise is recognised through government and industry funded research grants, and invitations to advise government and industry bodies on policy and dissemination of research outcomes and to serve on design and industry award juries.

Vishal Garg is Associate Professor and Head, Centre for IT in Building Science at IIIT Hyderabad. His research interests are in the areas of energy simulation and cool roofs.

Shankar Rajasekaran, Director Engineering, Impec Filters Private Limited is an engineering graduate from BITS, Pilani, a Certified Air Filter Specialist from NAFA, USA and a Certified Cleanroom Testing Professional from CTCBI, UK with more than 20 years of experience in manufacturing and testing of air filters.

Richie Mittal has 32 years of experience in energy efficiency, air conditioning and passive cooling-cum-ventilation. He is an ME in thermal engineering from Delhi College of Engineering, with a BE from Birla Institute of Technology. He is active in ASHRAE, ISHRAE, IGSHPA and MNRE. Presently he is a consulting engineer in the fields of HVAC&R, energy efficiency, renewable energy, green buildings, geothermal energy, air quality and third party commissioning under the name of Overdrive Engineering Pvt. Ltd.

Barun Aggarwal is Director at BreatheEasy, a division of Paharpur Business Centre. An ISHRAE member and a certified Climate Reality Leader trained by former US Vice President Al Gore, he specialises in IAQ, specifically testing, evaluation, remediation, occupant comfort and wellness. He has implemented NABERS (PALM), USGBC and is working on the first building in India for WELL certification. He brings disruptive and sustainable technologies in air and water. He has presented in various national and international forums.

V. Manjunath is a mechanical engineer with over two decades of HVAC experience, with expertise in implementing stage gate system for introduction of new products and services. He has been associated with BIS, ISHRAE, RAMA, BEE, etc. for developing standards, and was a member of ISHRAE-RAMA Standards Committee for liquid chillers. He was in the Principal Secretariat for solar photovoltaic standards development for MNRE's Jawaharlal Nehru National Solar Mission, and has been associated with regulators in the Middle East.

Rahul Aeron is National Sales Manager at Desiccant Rotors International, responsible for selling IAQ related products. He is a mechanical engineer from Raipur University, with more than 20 years of experience in sales of HVAC systems. His areas of interest are ventilation systems, air purification systems, RH control strategies and energy saving technologies.

Nitin M. Deodhar graduated with honors in mechanical engineering in 1987 and is a gold medalist with masters in environmental engineering. He has over 13 years of contracting experience, and has been in consulting for over 14 years now. He is interested in design of research oriented and novel greenfield projects, and is involved in detailed engineering of fitout projects. He is a LEED AP of USGBC and a certified Energy Manager by BEE.

Prof. M Ramgopal is a Ph.D. from IIT Madras. He is a Professor in Mechanical Engineering and Professor-in-charge, Refrigeration & Air Conditioning at IIT Kharagpur.

Ashwini Mehra is an Engineer from IIT-BHU, with management education from IIM Calcutta. He is a Past President, Delhi Chapter of ISHRAE. Presently, he is Executive Secretary of ISHRAE HQ.



Indian Society of Heating Refrigerating and Air Conditioning Engineers

K-43 (Basement), Kailash Colony, New Delhi -110048 (INDIA)

Ph.: +91-11-41635655, 29234925

Website.: www.ishrae.in

